

# Pump Out System for Sullage Disposal on Non-sewered Sites



## Plumbing Permit Number

PD

## Owners Details

Title:  Mr  Mrs  Ms  Miss

Given name(s)

Surname

Residential address

Suburb  Postcode

Phone  (W)  (H) Mobile

Email address

Owners Signature(s)

## Site Details

Site address

Suburb  Postcode

Lot number  Plan number

## Features

Site area   Existing Dwelling  New Dwelling

Number of fixtures:

<input type="checkbox"/> Kitchen sink	<input type="checkbox"/> Shower
<input type="checkbox"/> Dishwasher	<input type="checkbox"/> Bath
<input type="checkbox"/> Laundry tub	<input type="checkbox"/> Vanity
	<input type="checkbox"/> Other: (Specify)

## Physical System

Pump type  Head Pressure  
 Size of discharge hose  Length

Where installations are to be located adjacent to adjoining properties or dwellings the provision of a Sound Insulation Enclosure may be required.

## Guidelines

The following Guidelines are required to be complied with for the below ground dispersion of sullage waste (ie. Liquid wastes not polluted by human waste).

## Location

- Under no circumstances shall effluent be allowed to discharge above ground or onto adjoining properties.
- The effluent shall be pumped to approved below ground disposal trenches.

## Mechanical System

- Sullage shall be disposed of to a 450 litre holding tank designed to permit maximum pump out via an automatic motor and pump.
- The pump shall commence operation before the stored volume exceeds 120 litres
- Pump motor is to be connected to electricity via an underground connection if not adjacent to a building
- Maintenance of the pump out system is the responsibility of the owner and occupier

## Sullage Quality

- The system shall be used to accept waste not polluted by human wastes.
- Inputs to the system shall not include the human waste from the following:
  - Residues from stained nappies or nappy cleaning systems

To ensure that the above requirements are met, you would be required to submit an application form and supply details relating to the type of pump.

Where installations are to be located adjacent to adjoining properties or dwelling, the provisions of a Sound Insulation Enclosure may be required.

## Office Use Only

Approval is hereby issued for the installation of a permanent watering system in accordance with the attached plans.

Comments	<input type="text"/>		
<input type="text"/>			
<input type="text"/>			
<input type="text"/>			
<input type="text"/>			
Technical Officer	<input type="text"/>		
Fee paid	\$ <input type="text"/>	CSC	<input type="text"/>
Receipt	<input type="text"/>	Date	<input type="text"/>

CSBPS014 - 05/01/2015

**Information Privacy Act 2009** - Redland City Council is collecting your personal information in order to process this application. The information will only be used by authorised Council Officers for the purpose of a pump-out system for sullage disposal on non-sewered sites and ensuring our records are accurate. Your information will not be given to any other person or agency unless you have given us permission or we are required by law to do so.